

MUNICIPAL CORPORATION OF DELHI  
OFFICE OF THE DY. HEALTH OFFICER  
SHAHDARA NORTH ZONE


No. DHO/Shah (N)/2023/D-980

Dated: 10/3/23

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 336 dated 09.03.2023, the inspection of "GYANDEEP VIDYA BHAWAN SENIOR SECONDARY SCHOOL" at Block C-10, Yamuna Vihar, Delhi-110053 was carried out on dated 09.03.2023. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

  
9/3/23  
Dy. Health Officer  
Shahdara North Zone  
Deputy Health Officer  
Shahdara North Zone  
Municipal Corporation of Delhi

I.O.S.  
GYANDEEP VIDYA BHAWAN SENIOR  
SECONDARY SCHOOL  
Block C-10, Yamuna Vihar, Delhi-110053





# MICRO ENGINEERING & TESTING LABORATORY

(An ISO 9001:2015 & 14001:2015 Certified Laboratory)

Office  
I-4, First Floor, Mukund House,  
Azadpur, Delhi-110 033  
T: 011 48018197 | M: +91 9871143785

Laboratory  
Plot No. 43, HSIIDC, Indl. Estate,  
Rai, Sonapat, Haryana-131029  
T: 0130 4017631 | M: +91 9215515652

Email/Website  
info@metl.co.in  
metlson@yahoo.com  
www.metl.co.in

## TEST REPORT

Description of sample: Drinking Water

Report No. METL/RH/036 (103)/2023

Date of Report: 15/02/2023

Date of Receipt: 11/02/2023

Issued to:

Gyandeep Vidya Bhawan Senior Secondary School,  
C-10, Yamuna Vihar, Delhi-110053.

Requirement as per IS: 10500-2012; R-2018(Drinking Water)

S. No.	Characteristics	Test -Value	Acceptable Limit	Permissible Limit in absence of Alternate Source	Method of Test
1	Colour, Hazen unit. Max.	<5	5	15	IS-3025(P-4)-1983; R-2017
2	Odour	Agreeable	Agreeable	Agreeable	IS- 3025(P-5)-1983; R-2018
3	Turbidity, NTU. Max.	Nil	1	5	IS-3025(P-10)-1984; R-2017
4	pH Value	7.45	6.5 – 8.5	No Relaxation	IS-3025(P-11)-1983; R-2017
5	Total Hardness, (as CaCO <sub>3</sub> ), mg/l Max.	118	200	600	IS-3025(P-21)-2009; R-2019
6	Iron (as Fe), mg/l Max.	Nil	1.0	No Relaxation	IS-3025(P-53)-2003; R-2019
7	Chloride (as Cl), mg/l Max.	106	250	1000	IS-3025(P-32)-1988; R-2019
8	*Residual Free Chlorine, mg/l Min.	Nil	0.2	1.0	IS: 3025 (P-26)-1986; R-2019
9	Fluoride (as F), mg/l Max.	0.2	1.0	1.5	APHA 23 <sup>rd</sup> Edn. 2017
10	Total Dissolved Solids mg/l Max.	234	500	2000	IS-3025(P-16)-1984; R-2019

Remark: With respect to the above test, water sample conforms IS: 10500-2018. Water is suitable for drinking purpose.

Note: \*: To be applicable only when water is chlorinated.

\*\*\*\*END OF REPORT\*\*\*\*



### Terms & Conditions:

1. The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
2. Total liability of our Lab. is limited to the invoiced amount.
3. Samples will be destroyed after 30 days from the date of issuance of test report.
4. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.



Authorized Signatory