



# ADVANCE INSPECTION & TESTING LAB



B/119, Mayapuri Industrial Area, Phase 1, New Delhi-110064  
Web.: www.advancetestinglab.com, Email : advancetestinglab@gmail.com  
Tel: 91-9810-55-8484, 91-9891-35-3939

## TEST REPORT

FF:5.10.2.03

Issued To: M/s. Gyandeep Vidya Bhawan  
Block C-10, Yamuna Vihar  
Delhi- 110053  
India.

W.O. No: AITL/2690/06  
Report No: 24062906  
Date of Issue: 05-07-2024  
Date of Receipt: 29-06-2024  
Party Ref. No: PV & Verbal Dated 29-06-2024  
Order Confirmation Date: 29-06-2024

## SAMPLE PARTICULARS

Page 1 of 1

1. **Sample Packaging:** In Plastic bottle.
2. **Sample Quantity:** Approx 1 litre.
3. **Sample Description:** One sample described by party as Water for Drinking purpose, was received for following tests only.

## TESTS RESULTS

S.NO	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS:10500-2012)	CONFORMITY
1	Odour	IS:3025 (PART 5)-18 RA: 2022	Agreeable	Agreeable	YES
2	Taste	IS:3025 (PART 7)-17 RA: 2022	Agreeable	Agreeable	YES
3	Colour, Hazen Units	IS:3025 (PART 4)-21	<5	A. 5 max as acceptable limit B. 15 max as Permissible Limit	YES
4	pH Value	IS:3025 (PART 11)-22	6.8	6.5 to 8.5	YES
5	Total Dissolved Solids, mg/l	IS:3025 (PART 16)-23	118	A. 500 max as acceptable limit B. 2000 max as permissible limit	YES
6	Turbidity, NTU	IS:3025 (PART10)-23	<1	A. 1 max as acceptable limit B. 5 max as permissible limit	YES
7	Chloride as Cl, mg/l	IS:3025 (PART 32)-88 RA: 2019	15.0	A. 250 max as acceptable limit B. 1000 max as permissible limit	YES
8	Calcium as Ca, mg/l	IS:3025 (PART 21)-09 RA: 2023	11.8	A. 75 max as acceptable limit B. 200 max as permissible limit	YES
9	Magnesium as Mg, mg/l	IS:3025 (PART 46)-23	7.1	A. 30 max as acceptable limit B. 100 max as permissible limit	YES
10	Total Hardness as CaCO <sub>3</sub> , mg/l	IS : 3025 (PART 21)-09 RA: 2023	58.8	A. 200 max as acceptable limit B. 600 max as permissible limit	YES
11	Flouride as F, mg/l	IS:3025 (PART 60)-23	<0.1	A. 1.0 max as acceptable limit B. 1.5 max as permissible limit	YES
12	Iron as Fe, mg/l	IS:3025 (PART 53)-03 RA: 2023	<0.1	A. 0.3 max as acceptable limit	YES
<b>BACTERIOLOGICAL TESTS</b>					
13	Total Coliform bacteria /100ml	IS: 1622-1981 RA: 2019	Absent	Shall not be detectable in any 100ml sample	YES
14	E.Coli/100ml	IS: 1622-1981 RA: 2019	Absent	Shall not be detectable in any 100ml sample	YES

Remark: The sample confirms to IS: 10500-2012 w.r.t to above tests only.

\*\*\*\*

*Virender Taandon*

DR. VIRENDER TAANDON

Authorised Signatory

### Civil / Mechanical / Chemical / NDT TESTING

1. The results listed refer only to tested samples and applicable parameters. Endorsement of product is neither inferred nor implied. 2. Total liability of our lab is limited to the invoiced amount. 3. Samples will be destroyed after 15 days from the date of test certificate unless specified otherwise. 4. The Report shall not be reproduced except in full without written approval of Laboratory. 5. Report refers to the sample submitted to us and not drawn by Advance Inspection & Testing Lab unless mentioned otherwise. 6. In case of any dispute, the Jurisdiction shall be New Delhi Courts.

**MUNICIPAL CORPORATION OF DELHI  
OFFICE OF THE DY. HEALTH OFFICER  
SHAHDARA NORTH ZONE**

No. DHO/Shah (N)/2024/D-255


Dated: 08/07/24

**SCHOOL INSPECTION REPORT**

In reference to your application duly submitted in the office of undersigned vide diary no. 599 dated 05.07.2024, the inspection of "GYANDEEP VIDYA BHAWAN SENIOR SECONDARY SCHOOL" at Block C-10, Yamuna Vihar, Delhi-110053 was carried out on dated 05.07.2024. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

**Principal  
GYANDEEP VIDYA BHAWAN SENIOR  
SECONDARY SCHOOL  
Block C-10, Yamuna Vihar, Delhi-110053**

  
**Dy. Health Officer  
Shahdara North Zone**  
उप-शाहदरा उत्तरी क्षेत्र  
दिल्ली नगर निगम